

**FRONT RANGE FIRE RESCUE**  
**Temporary Fireworks Sales Permit Inspection Checklist**  
*Based on the adopted International Fire Code*

FIREWORKS VENDOR NAME

PHONE #

--	--

*The following checklist applies only to inspecting a tent, canopy and/or membrane structure that is erected in conjunction with a permit issued by FRFR for temporary sale of fireworks.  
 All checklist items shall be completed by the FIREWORKS VENDOR prior to requesting an inspection by FRFR.  
 The FIREWORKS VENDOR shall maintain copies of all information on-site and available for inspection.*

<b>Any deficiency must be corrected prior to issuance of any permit. Failure to correct deficiency prior to inspection shall result in a re-inspection and payment of applicable re-inspection fees.</b>		
<b>Deviation from any requirement below must receive approval from the Fire Code Official.</b>		
<b>Vendor Initials</b>	<b>FRFR Initials</b>	<b>GENERAL SITE PLAN MATERIALS PROVIDED FOR FRFR REVIEW PRIOR TO PERMIT ISSUANCE</b>
		General site plan, showing proposed location of tent/canopy in relation to adjacent buildings, rights-of-way, lot lines, etc. (3103.6) The site plan will be sent to FRFR when requesting a permit.
		Description of proposed interior layout of sales stand (3103.6)
		Certificate of flame resistance is provided for tent/canopy (3104.2)
		Fireworks Vendor shall maintain a copy of FRFR policy for Temporary Fireworks Stands on site
		FRFR Permit for Temporary Fireworks Sales
<b>STRUCTURAL INFORMATION</b>		
		Sales stand adequately braced and/or anchored to withstand weather and prevent collapsing (3103.9)
		“No Parking” signs are in place to restrict parking within 25 feet of sales stand (3103.8.2)
		Generators must be at least 20 feet from tent structure (3104.19)
		LPG cylinders and/or fuel storage for generator must be at least 20 feet from tent structure (3104.19)
<b>MEANS OF EGRESS AND SIGNAGE</b>		
		At least two (2) means of egress shall be maintained at all times (3103.12.8)
		Exits shall be clearly marked (3103.12.6)
		“No Smoking” signs prominently displayed throughout and within 25 feet of sales stand (3104.6)
<b>FIRE EXTINGUISHERS AND FIRE SAFETY</b>		
		Fire extinguishers shall be properly mounted and readily accessible (3104.12)
		Every fire extinguisher must be inspected and serviced annually by a licensed contractor
		Every tent shall be provided with a minimum of two 2-A:10-B:C extinguishers
		Combustible vegetation within 25 feet of sales stand shall be mowed and/or removed (3104.21)
		No combustible materials/vegetation within structure (3104.5)
		No open flame, fire or heat sources permitted within sales stand (3104.7)
		Signs posted restricting open flame, fire or heat sources within 25 feet of sale stand
<b>FIREWORKS STATUTES</b>		
		Appropriate signs are posted indicating age restrictions for purchasing and/or possessing fireworks.
		Type IV fireworks storage magazine is located at least 25 feet from tent.
		Fireworks storage magazine is kept locked when not in use.
		Fireworks storage magazine is appropriate marked/labeled.
		Displayed fireworks are visually examined for compliance as Permissible Fireworks
		Stored fireworks are visually examined for compliance as Permissible Fireworks
<b>Items noted as deficient must be corrected before permit is signed by FRFR. A re-inspection fee must be paid by the installation contractor if the deficiency cannot be corrected immediately and a repeat inspection is needed.</b>		

Notes: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_